

A plant generates steams for either heating purpose or for generating electricity or for both.

Steam produced by evaporating water is known as saturated steam. Because of its moisture contents, this steam spreads heat evenly over heating surface and therefore heat transfer is good. This steam has a definite temperature at the pressure it is generated. It is best to use saturated steam for heating requirement of plant.

For generating power steam or running the turbine blade, it is good to use superheated steam, another kind of steam produced by further heating the saturated steam. Saturated Steam is made to pass through Superheater coils in which, the moisture of saturated steam are evaporated. This steam has higher temperature compared to the saturated steam at the same pressure. Superheated steam, because of lack of moisture, behaves like a gas containing more of kinetic energy.

To run turbine blades the steam needs to be having more of a kinetic energy and must be free from moisture as moisture is undesirable with moving parts. Superheated steam is therefore the best medium to run turbine and generate electricity.

Often the turbine has a bleeding and / or has exhaust steam coming out, after it has been used by turbine. This steam can be re-used in heating process by DESUPERHEATING it.

In DESUPERHEATING process the moisture, which was earlier evaporated in Superheater, is added by injecting water, making it evaporate by absorbing superheat.

Advantage of using Desuperheater:

Using Desuperheater has following advantages:

- Superheated steam behaves like gas, leaving hot and cold patches over a heating surface, resulting in poor heat transfer, wasting valuable steam. Heat transfer is even with Desuperheated steam as it behaves like vapor
- Generates equal amount of steam from water, as injected water is converted in to steam.
- Heating process becomes faster enhancing plant efficiency.

How does a Desuperheater work ?

Moisture particles of saturated steam, that were further heated (and almost eliminated) to produce Superheated steam, are gained again by injecting water into superheated steam, through a Desuperheater. A simple heat balance formula "The amount of heat to be absorbed should be equal to the amount of heat to be gained by water," is used to calculate the required amount of water for required temperature reduction.

A job of a Desuperheater is to evaporate the injected water in a shortest time so that temperature sensing element can be placed as close as possible from the point of water injection (but only after the water is converted into steam and the required temperature is achieved). Change in the direction of outlet pipe of Desuperheater should be effected only after the water is evaporated. This will prevent water logging and worst still, water hammering in the pipelines. An efficient Desuperheater can therefore allow change in pipe direction in a shortest distance offering that much more flexibility in piping.



DeFlo

MINI, VSD and Steam Conditioning valve (SCV)

Factors enhancing the efficiency of a Desuperheaters :

Pressure Differential between water and steam (Superior pressure) :

This has to be as high as possible as water is to be accepted by steam and therefore must be at a higher pressure than that of steam to be Desuperheated. The Higher the pressure differential, the better will be the atomizing effect and smaller will be the size of water particles. Smaller water particles evaporate faster than the bigger ones resulting in a speedy Desuperheating process.

Velocity Differential between water and steam :

This is an inherent property of piping engineering. Pipe for water are sized at about 1.5~2 M/sec. velocity as against that of steam pipes, which are sized at 40~50 M/sec. Higher velocity differential helps water to tear apart, resulting in better atomization.

Temperature differential between water and steam :

This should be as minimum as possible. Water at near saturation temperature, evaporates faster as it has to absorb very little amount of heat for getting converted into steam. This calls for higher amount of water but will produce more steam and has substantial importance on the efficiency of a Desuperheater.

Turbulence :

This too has a great importance. Water coming out of a Nozzle with swirl will ensure through mixing with steam as turbulent water particle mixes with steam with impact and that will further enhance the efficiency of a Desuperheater.

Whilst the first three factors are in control of the Desuperheater users the fourth one is engineered by Desuperheater manufacturers. Users must see the importance of these factors and provide them, so that he, in turn can have an efficient Desuperheater in his plant.

We manufacture two types of Desuperheaters :

- Simple Spray Mini Desuperheater DeFlo (Mini)
- Variable Spray Desuperheater DeFlo (VSD)

Mini Desuperheater DeFlo (Mini)

This is the most basic type of Desuperheater, consisting of a fixed area jets arranged to face Steam flow through periphery of Desuperheating pipe. The MINI relies on the pressure differential available across the jets to achieve the conditions for rapid absorption of the water into the steam.

Cooling water control valve installed in the line ahead of the MINI will vary in water supplied to the jets to maintain the downstream steam temperature at the measuring point. Whilst the MINI is working between about 5 and 100% of maximum rated capacity, there will be adequate pressure differential across the jets to ensure a spray pattern in the form of a star of finely divided water particles. When Desuperheating load goes above the maximum, the steam velocity at the exit of the jets will ensure turbulent flow, helping mix water particles in to the steam thoroughly. With reduction in steam flows the amount of steam

and the turbulence will also reduce. With the reduced steam flow the water requirement will also be proportionately reduced in order to maintain the constant temperature. Plug of the control valve will automatically move towards the closed position to achieve this.

Since the jets have a fixed orifice the pressure differential across it will reduce proportional to the square of the reduction flow in accordance with Bernoulli's law. This causes a reduction in differential velocity between the steam and the water particles, a reduction in the cone angle so that the water is projected more directly downstream, and an increase in water droplet size and all of these phenomena adversely affect the ability of the Desuperheater to work efficiently.



MINI or Simple spray Desuperheaters relies upon the pressure drop across the spray jets to achieve the necessary atomization. The unit consists of an orifice plate type jets through which the water is discharged and the pressure drop across this creates a spray pattern to achieve the necessary atomization. The Desuperheater can only be designed for maximum flow condition and since the pressure drop across the jet hole follows the square laws, as the flow is reduced, the pressure drop across the jet hole is substantially reduced and the atomizing characteristic is rapidly lost. For, example, if the flow is reduced by 50%, the pressure drop across the jet is reduced by 4.


If the load further reduces, a stage would be reached where the jet ceases spraying and the water is projected straight downstream unit and collects at the bottom of the steam pipe. Since the steam is not being Desuperheated the temperature senses a rise in steam temperature, the control valve plug moves towards the open position and the nozzle commences to spray again, but at too high a rate of steam flow at that time. The steam is thus overcooled causing the control valve to close again. The whole cycle then repeats with consequent swings in temperature and intermittent flooding of the steam line with cooling water.

Many attempts have been made to produce a nozzle having a better rangeability such as swirl nozzles but they still suffer the fact that as steam and water flow reduces, this mechanical phenomena result in Desuperheating efficiency fall away proportional to the square of the flow.

More recently different designs of variable nozzle spray type Desuperheaters have been attempted. In these designs it is intended to maintain constant water pressure differential to ensure good atomizing, a wide angle cone and high water velocity at all loads, changing the orifice area proportionally to load varies throughout.

However, the MINI is widely used with good results in those installations, where the load is relatively steady. The inevitable variation in the steam temperature downstream of the Desuperheater and the water, which is collected and trapped out are of low order, to be acceptable





Variable Spray Desuperheater (VSD)

In order to recover loss of performance in a Mini or simple spray Desuperheater under low load conditions, variable nozzle spray type Desuperheater are recommended where, as the load is reduced, the spray nozzle area is also reduced. The variable nozzle spray Desuperheater represents major advance in the design of Desuperheaters. It is small enough to mount through a ND 80 mm flange in the steam main having a minimum of 6 meters of straight pipe work downstream of the nozzle. It can be also mounted on pipe bends.

The variable nozzle spray Desuperheater (VSD) provides more economical control of steam temperature by introducing cooling water into the steam flow and through a nozzle of advance design. In this design water pressure above steam pressure is used to produce a thin film of conical spray of water which soon evaporates as it is injected into the steam flow. ***This design of Desuperheater, eliminates the need for a separate water control Valve.***

The valve is accurately built into the Desuperheater. Because there is no external water control valve maximum water pressure is always available at the nozzle.

The equal percentage characteristic plug controls the amount of atomized water being injected. As per signals of the temperature controller the valve plug varies the area of the nozzle and the water which is guided through a cage with a few water inlet orifices, progressively uncovers as per the lift of the plug. Water flow is controlled at the point of injection into the steam.

The VSD Desuperheater utilizes constant water pressure to create a fine conical spray of water injected into the moving steam. The Desuperheater water spray evaporates quickly, eliminating the impingement on the piping walls.


The actuator moves the Desuperheater control plug, which regulates the quantity of water (not the pressure) injected into the steam.

Due to its unique design the VSD Desuperheater offers considerable advantage to the users.

DeFlo

MINI, VSD and Steam Conditioning valve (SCV)

- This is a compact device in which Pressure Reducing and Desuperheating Process take place simultaneously.
 - Vary effective, space and cost saving compared to the conventional Pressure Reducing cum Desuperheating station (PRDS) that have three isolating valves EACH around both, pressure and flow control valve. Such PRDS offer manual stand by operation.
 - Having two SCV (one in operation and one standby) can offer uninterrupted automatic operation with economical cost, requiring lesser space.
 - SCV are most efficient way of steam conditioning in which, water is injected in a highly turbulent area so that enormous pressure and velocity differential is available for efficient mixing of water with steam.
- Mascot SCV have following advantages :
- Configuration: Globe inline or Angle with expanded outlet where required.
 - Spray method: Small jets of spray through stainless sleeve at the outlet flange makes this system absolutely simple.
 - No special trim / expertise needed as Mascot SCV uses standard control valve spares.
 - Water is sprayed in a way that the SCV is well protected for pitting and thermal stress / shocks, unlike other conditioning valves that allows water to be sprayed in a belly of valve body.
 - Available sizes and pressure ratings: 0.5" to 24" in 150# to 4500# pressure ratings.
 - Good until turndown ratio of 80:1
 - Pressure Reducing and Desuperheating is a process that is all about the Control.
 - Mascot is one of the TWO specialists of Control valves, world over, who are in the field of Pressure Reducing and Desuperheating business



PRDS and DSH are tailor made items and can also be manufactured to retrofit in your existing pipe work.



MASCOT VALVES PVT. LTD.

166 / 167, G I D C, Naroda, Ahmedabad : 382330. India
Phone : +91 79 22821619/22823369, Fax : +91 79 22822430
Email : info@mascotvalves.com / web : www.mascotvalves.com